

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)

BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION 11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA) Ruskin Company

3900 Dr. Greaves Road Grandview, MO 64030

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Model PHB637HDXD Aluminum Penthouse Louver

APPROVAL DOCUMENT: Drawing No. 60-021966, titled "PHB637HDXD PENTHOUSE", sheets 1 through 13 of 13, prepared by Ruskin Company, dated 01/09/2006, with last revision H dated 09/22/2015, signed and sealed by Chelsea GO Welch, P.E., bearing the Miami-Dade County Product Control revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, Geneva, AL, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

LIMITATION: This system is to be installed in a location where the room behind the louver is designed to drain water penetrating into the room, and the room will house water resistant/water proof equipment, components, or supplies.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA # 12-0203.15 and consists of this page 1 and evidence page E-1, as well as approval document mentioned above.

The submitted documentation was reviewed by Carlos M. Utrera, P.E.

MIAMI-DADE COUNTY
APPROVED

11/23/2015

NOA No. 15-0930.09 Expiration Date: April 26, 2017 Approval Date: December 3, 2015

Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Drawing No. 60-021966, titled "PHB637HDXD PENTHOUSE", sheets 1 through 13 of 13, prepared by Ruskin Company, dated 01/09/2006, with last revision H dated 09/22/2015, signed and sealed by Chelsea GQ Welch, P.E.

B. TESTS "Submitted under NOA # 06-1101.08"

1. Test report on TAS 201-Large Missile Impact Test, TAS 203-Cyclic Wind Pressure Test and TAS 202-Uniform Static Air Pressure Test titled "Ruskin Company STRUCTURAL PERFORMANCE TEST", prepared by National Certified Testing Laboratories, Test Report # 210-3247.2, dated 06/16/2006, signed and sealed on 08/03/2006 by Gerard J. Ferrara, P.E.

C. CALCULATIONS

1. Wind load review prepared by Ruskin Company, dated 09/12/2015 signed and sealed by Chelsea GQ Welch, P.E.

"Submitted under NOA # 12-0203.15"

2. Structural and anchoring calculations for PHB6375DXD Hinged Roof Penthouse, 23 pages, complying with the 2007 FBC, prepared by Daniel J. Rau P.E., signed and sealed on 01/24/2012 by William J. Mossie, P.E.

D. OUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS


1. Statement letter of code conformance to the 5th edition (2014) FBC issued by Ruskin Company, dated 09/22/2015, signed and sealed by Chelsea GQ Welch, P.E.

"Submitted under NOA # 12-0203.15"

- 2. Statement letter of code conformance to 2010 FBC issued by Ruskin Company, dated 04/11/2012, signed and sealed by William J. Mossie, P.E.
- 3. Statement letter of no financial interest issued by Ruskin Company, dated 01/24/2012, signed and sealed by William J. Mossie, P.E.

Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 15-0930.09
Expiration Date: April 26, 2017

Expiration Date: April 26, 2017 Approval Date: December 3, 2015



NOTES: ®

- 1) THE PHB637HDXD HAS BEEN TESTED IN ACCORDANCE WITH FLORIDA PROTOCOLS TAS-201, 202 & 203 FOR LARGE MISSLE IMPACT, UNIFORM PRESSURE AND CYCLIC WIND PRESSURE.
- 2) THIS PENTHOUSE SYSTEM IS APPROVED FOR APPLICATIONS WITH DESIGN PRESSURES OF $\pm /-$ 110 PSF OR LESS.
- 3) IT SHALL BE THE RESPONSIBILITY OF THE PERMIT HOLDER/BUILDING DESIGN ENGINEER OF RECORD TO VERIFY THE STRUCTURAL INTEGRITY OF THE ROOF CURB/STRUCTURE TO SUPPORT THE LOADS IMPOSED BY THIS PENHOUSE SYSTEM.
- 4) 'A'+12" AND 'B'+12" ARE THE OUTSIDE DIMENSIONS OF THE PENTHOUSE SIDES. 'A' AND 'B' ARE THE INSIDE DIMENSIONS OF THE CURB.
- 5) THE MAXIMUM OUTSIDE DIMENSIONS OF THE PENTHOUSE ARE 96"X108"X84" TALL AS INDICATED ON THESE DRAWINGS. THE MINIMUM OUTSIDE DIMENSIONS OF THE PENTHOUSE ARE 24"X24"X12" TALL.
- 6) SEALING REQUIREMENTS AROUND THE PENTHOUSE SHALL COMPLY WITH THE PROVISIONS OF CHAPTER 15 OF THE FLORIDA BUILDING CODE.

- 7) ABBREVIATIONS: NIRC = NOT IN RUSKIN'S CONTRACT
- 8) ALL FASTENERS SHALL BE CORROSION RESISTANT.

- - WELD FRONT HOOK OF BLADE BRACE TO BLADE HOOK. WELD ONE SIDE AT CORNERS, BOTH SIDES AT INTERMEDIATE HVBS.

1/8 2


- HVBS (REF.)


- WELD BLADE BRACE TO CORNER ANGLE AND HVBS, FULL HEIGHT OF BLADE BRACE.
- WELD BLADE BRACE TO TOP OF BLADE, WELD ONE SIDE AT CORNERS, BOTH SIDES AT INTERMEDIATE HVBS.


AND DETAILS


GENERAL REVISIONS \oplus DLB | KJM | NLT | CGW | 9/22/15 REVISED NOTE 7 REVISED O.D. LOCATIONS (F) RAT 09/18/07 MODEL NAME CHANCE (E) DAR VMA VMA EXTENDED SILL (NOT VISIBLE) **(D)** RFM DJR VMA 5-3-06 REMOVED SILL FROM ISOMETRIC **©** WRT 2/21/06 CHELSEA G. WELCH ADDED OFFICE USE BOX ՛₿ WRT DJR I DJR 2/8/06 ENGRIEURING DISCIPLINE (CIVIL/STRUCTURAL CHANGED HEAD CHANNEL $\langle A \rangle$ DJR l DJR 2-3-2006 RECRUSTRATION HUMBER (H) FL #67221 REVISION DESCRIPTION CHK'D. DATE DWAL WRT BY: DJR BY: DJR BY: RUSKIN Mfg Grandview, MD TE7/11/05 DATE:1/9/06 DATE:1/9/06 DATE: NONE PHB637HDXD PENTHOUSE SHEET 1 OF 13 (F) SPECS, NOTES 60-021966-00D











		oximes		TABLE 1		
· [INE ITEM	SHEET NUMBER	MATERIAL	DESCRIPTION	RUSKIN NUMBER	1
Γ	1	7	6063-T6 ALUM	HEAD CHANNEL	-	1
Γ	2	7	(H)6063-T6 ALUM	LOUVER SILL FRAME	70-021130-00B	1
	3	7	⟨H⟩6063-T6 ALUM	LOUVER JAMB FRAME	70-020691-00B	√B>
	4	7	(H)6063−T6 ALUM	LOUVER BLADE	70-020560-00B	1
	5	7	⟨H⟩6063-T6 ALUM	BLADE BRACE	70-020568-00B	1
	6	. 8	6063-T6 ALUM	6" HVBS	70-021465-00B	1
	7	9	6063-T5 1/8" ALUM(H)	6"X3" RECT. TUBE ROOF SUPPORT		1
	8	9	6063-T6 1/8" ALUM	4"X1" RECT. TUBE SUPPORT (SHORT)	_	1
	9	, 9	6063-T6 1/8" ALUM	4"X1" RECT. TUBE SUPPORT (LONG)	_	1
	10	9	5005-H34 1/8" ALUM(H	WATER SEAL	_	7
Γ	11	10	3003-H14 3/8" ALUM	SPECIAL LIFTING LUG	_	1
	12	11	5005-H34 .080" ALUMH	LEFT HAND CORNER FLASHING	_	1
E	13	11	5005-H34 .080" ALUMH	RIGHT HAND CORNER FLASHING	_	┦ ;
	14	_	6063-T6 ALUM	2"X2"X1/4"X84" ANGLE	_	1
	15	10	⟨⊞⟩ 6063–T6 ALUM	END CAP 12" LONG	70-021389-00B	1
	16	10	6063-T5 ALUM	SCREEN FRAME	70-021197-00A] .
	17	_	PLATED STEEL	#10-16X1" TEK SCREW	_]
	18A	10	⟨H⟩5005−H34 ALUM	78" LONG SILL SUPPORT	_	1
	18B	10	(H)5005−H34 ALUM	90" LONG SILL SUPPORT	· <u>-</u>	1
	19	12	GALV. STL.	2" WIDEX3/16"X87"DIAGONAL STRAP	_	1
	20	12	3003-H14 .080" ALUM	PENTHOUSE ROOF SKIN	_	٦
8 [21	12	5052 ALUM	$\langle \overline{F} \rangle \rangle = 4X96 \text{ HINGE} - 1/8" \text{ THK., } 3/8" \text{ PIN, } 2" \text{ KNUCKLE}$	85-022110-00B	$\exists \langle H \rangle$
	22	12	3003-H14 ALUM	1 1/2"X1 1/2"X1/8"X2" CLIP ANGLE	85-020366-00B	1
©[23	_	PLATED STEEL	5/8"X1 1/2" HHB W/ WASHER, LOCKWASHER & HEX NUT	_	1
	24	_	PLATED STEEL	1/4"X1" HHB W/ LOCKWASHER & HEX NUT	_	1
$_{L}L$	25	12	GALV. STL.	2" WIDEX3/16"X88" DIAGONAL STRAP	_	1
©(26	-	PLATED STEEL	3/8" X 1 1/2" HHB W/ WASHER, LOCKWASHER & HEX NUT	_	1
$^{\circ}$	26A	-	PLATED STEEL	3/8" X 1 1/2" PLATED STEEL SELF TAPPING SCREW	_	1
_[27	13	(H)5005−H34 ALUM	4 7/16"X95 7/8"X.080" HINGED DOOR END PLATE	-	1
	28	—	PLATED STEEL	#10 WASHER	_	7
$^{\circ}$	29	-	⟨H⟩5005−H34 ALUM	FILLER BAR-1/8" THK., 9" LONG		1

BASE MATERIAL	EDMENT	— 3" FROM CORNERS & 12" MAX. O/C, SEE TABLE 2 FOR FASTENER REQUIREMENTS
_	→ EDGE [DISTANCE
© CURB ANCHOR DE	<u> FAILS</u>	

FOR OFFICE USE ONLY

PRODUCT REVISED as complying with the Florida Puilding Code
Acceptance No 15-07-30,07
Expiration Date 04-12-12-17
By Miami Unite Product Control

DLB KJM NLT

DJR VMA VMA

DAR VMA VMA

RFM DJR VMA

DJR DJR VMA

CHK'D. BY: CGW 9/22/15

8-28-06

5-18-6

5-4-06

2-6-2006

DATE

APPV'D. BY:

TABLE 2 (FXH)						
BASE MATERIAL	FASTENER TYPE	SPECIAL REQUIREMENT				
WOOD FRAME	3/8" DIA. LAG SCREW	3" MIN. EMBEDMENT, 1 1/2" MIN. EDGE DISTANCE, S.G. = 0.42				
STEEL DECKING	3/8" DIA. SELF-TAPPING SCREW	9/16" MIN. EDGE DIST., 10 GAUGE MIN. THICKNESS				
CONCRETE	3/8" DIA. HILTI KWIK BOLT III EXP. ANCHOR OR EQUAL	2 1/2" MIN. EMBEDMENT AND EDGE DISTANCE, 2000 PSI MIN.				

REGRISTRATION NUMBER FL #67221

S _					
ENGINEER OF RECORD	DWN.	CHK.	APPV'D.	APPV'D.	Τ
CHELSEA G. WELCH	BY: WKI	IBX: DAK	IBX: DJK	BY:	
N CHELSEA G. WELCH	DATE:	DATE:	DATE:	DATE:	
¹ /	<u> 12/16/05</u>	<u> 1/9/06</u>	1/9/06		
ENGINEERING DISCIPLINE					
-L CIVII /CTDHCTHDAI					

PHB637HDXD PENTHOUSE
ITEM LIST AND APPROVED

TABLE

RUSKIN MFG

GENERAL REVISIONS

MODEL NAME CHANGE

MODIFIED DWG NUMBER COLUMN DATA

MODIFIED DWG NUMBER COLUMN DATA

REVISION DESCRIPTION

REVISED HINGE #, PROVIDED ANCHOR DETAILS

 $\langle H \rangle$

 $\langle F \rangle$

 $\langle E \rangle$

 $\langle A \rangle$

CHANGE LETTER


GRANDVIEW, MO
PLOT SCALE
BY:
DATE:
DWG. NO.


ENTHOUSE
APPROVED

PLOT SCALE
BY:
DATE:

APPV°D. BY:


SHEET 6 OF 13(H)





(B) PLANT REF: 70-020691-00B

<u>ITEM 3 - LOUVER JAMB FRAME</u>



ITEM 5 - LOUVER BLADE BRACE

5.964 56.543

NOTES: 1. REF SHEET 6 FOR MATERIAL (H)

PRODUCT REVISED
as complying with the Florida
Building Code Misma Dade Product Control

<u> ITEM 4 – LOUVER BLADE</u> ENGINEER OF RECORD CHELSEA G. WELCH ENGINEERING DISCIPLINE CIVIL/STRUCTURAL REGRISTRATION NUMBER WRT BY: DJR BY: DJR BY: BY: DATE: 12/16/05 DATE: 1/9/06 DATE: 1/9/06

PLANT REF: 70-021045-008

 $\langle A \rangle$ CHANGE LETTER **RUSKIN MFG** PHB637HDXD PENTHOUSE

GENERAL REVISIONS $\langle H \rangle$ DLB | KJM | NLT CGW 9/22/15 $\langle E \rangle$ MODEL NAME CHANGE DAR |VMA|VMA 5-18-6 CHANGED DWG # TO 70-020691-00B RFM DJR VMA 5-4-06 CHANGED DWG CONTENT DJR VMA 2-6-2006 CHK'D. BY: APPV'D. BY: APPV'D. REVISION DESCRIPTION BY: DWG. CERTIFIED PLOT SCALE GRANDVIEW, MO

PART DETAILS

NONE


DWG. NO.


DATE:


60-021966-00B

ONLY USE OFFICE FOR

SHEET 7 OF 13 (H)







18 WATER SEAL AT END DETAIL

NTS

1. REF SHEET 6 FOR MATERIAL (H) ONLY PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 15-0930,09
Expiration parts 04/12/100 USE OFFICR Miarui Dade Product Control FOR

NOTES:

ı	Evenies of se					
	ENGINEER OF RECORD					
	CHELSE	EA G. W	/ELCH			
$\langle \Box \rangle$						
	ENGINEERING DIS					
\[``\	l CIVIL/S	STRUCTU	IRAL			
			· · · · · · · · · · · · · · · · · · ·			
	REGRISTRATION N					
	FL #67	/221				
			[Va			
	DWN. BY: WRT	снк. ву: DJR	APPV'D. BY: DJR	APPV'D. BY:		
	DATE:	DATE:	DATE:	DATE:		
	12/16/05	1/9/06	1/9/06			
			· -			
		SHEET 9	OF 13 (F	Ŋ		
		SHEET 5	01 10 (ע		

	H	GENERAL REVISIONS	DLB	KJM	NLT	CGW	9/22/15
	Œ	MODEL NAME CHANGE	DAR	VMA	VMA		5-18-6
	A	CHANGED DWG CONTENT	DJR	DJR	VMA		2-6-2006
	CHANGE LETTER	REVISION DESCRIPTION	DWN. BY:	CHK'D. BY:	APPV'D. BY:	APPV'D. BY:	DATE
	RUSKIN MFG		PLOT SCALE		DWG. CERTIFIED		
			NONE		BY:		
					DATE:		
	PHB637HDXD PENTHOUSE PART DETAILS		DWG. NO				
			$\langle H \rangle$				
			60-021966-0ÖB				iR

